

ORDINANCE NO. 1267

AN ORDINANCE OF THE CITY OF REDLANDS AMENDING THE
REDLANDS ORDINANCE CODE BY ADDING CHAPTER 42 THERETO

THE CITY COUNCIL OF THE CITY OF REDLANDS does ordain as
follows:

SECTION ONE. That the Redlands Ordinance Code be
amended by the addition of the following sections.

CHAPTER 42

Article 420	Adoption 1961 Uniform Fire Code
421	Fire Code & Appendixes Adopted in Part
422	Establishment & Duties of Division of Fire Prevention

Article 420

Adoption of the 1961 Uniform Fire Code

4201. The herein designated portions of the Uniform Fire Code, 1961 edition and Appendix A, Appendix C, Appendix E and Appendix G thereto providing regulations consistent with nationally recognized standard practice, to safeguard life, health, property and public welfare to a reasonable degree from the hazards of fire and explosion arising from the storage, use and handling of dangerous and hazardous materials, substances and devices, the operation, installation, construction location, safeguarding and maintenance of attendant equipment, and the installation and maintenance of adequate means of egress not provided for by the Building Code, which Fire Code was approved by the California Fire Chiefs Association Conference held May 17, 1961. Three copies of said code and said appendixes have been certified as true copies and filed in the office of the City Clerk and hereby adopted by reference. The parts of said code and appendixes so adopted by reference are made a part of this ordinance as though set forth at length herein (Ordinance No. 1267).

Article 421

Fire Code and Appendixes Adopted in Part

4210. The Uniform Fire Code and Appendixes A, C, E and G, with the exception of the parts and provisions expressly excepted and deleted and as amended by this Section 2, are adopted by reference and made a part hereof as provided in Section 1 hereof. The sections, paragraphs and parts of said Uniform Fire Code which are excepted, deleted and not adopted include:

Section 1.24;	Section 13.24;	Section 13.33;
Section 13.35;	Section 13.36;	Section 13.37;
Section 17.05;	Section 17.06;	Section 23.04;
Section 23.05;	Section 27.14;	Section 27.15;
Section 27.24;		

4211. The following paragraphs and parts of said Uniform Fire Code are adopted as amended.

4212. Subsection (d) of Section 10.01 of the Uniform Fire Code is hereby amended to read as follows:

(d) All doors in or leading to required exitways shall be kept unlocked at all times when the building or floor area served thereby is occupied by customers.

4213. Section 15.104 of the Uniform Fire Code is hereby amended to read as follows:

Section 15.104 Container, Tanks, Equipment, and Apparatus. Containers, Tanks, Equipment and Apparatus used or intended to be used for the storage, handling, use or sales of flammable liquids shall be of an approved type. Glass containers exceeding 32 fluid ounces in capacity shall not be approved except where contamination is a factor. Samples of not to exceed one quart of capacity may be taken in glass containers for commercial reference or testing.

4214. Subsection (a) of Section 15.103 of the Uniform Fire Code is hereby amended to read as follows:

(a) Storage, handling or use of Class I, Class II or Class III-A flammable liquids in containers exceeding one gallon in aggregate capacity in a dwelling or other place of human habitation; or in excess of six (6) gallons in any other building or other occupancy; or in excess of ten (10) gallons outside of any building; except that no permit shall be required for the following:

(1) For the storage or use of flammable liquids in the fuel tank of a motor vehicle, aircraft, motorboat, mobile power plant or mobile heating plant.

(2) For the storage or use of paints, oils, varnishes or similar flammable mixtures when such liquids are stored for maintenance, painting or similar purposes for a period of not more than 30 days.

4215. Article 15 of the Uniform Fire Code is hereby amended by adding thereto a new section numbered 15.225 to read as follows:

Section 15.225 Abandonment

The following procedure shall govern and control abandonment or removal of underground flammable liquid tanks:

(1) Underground flammable liquid tanks are hereby deemed "out of service" when one of the following occurs:

- a) Whenever the owner or user shall so state,
- b) Whenever the dispensing apparatus is disconnected,
- c) Whenever there is a discontinuance of the use of the tank or its appurtenances for the purpose for which it was designed for a continuous sixty day period.

(2) Underground tanks taken out of service shall be disposed of in any of the three following manners:

- a) Being placed in "temporarily out of service" condition,
- b) Abandoned in place,
- c) Removed.

(3) The owner, operator or person in control of a tank deemed "Out of Service" shall notify the Division of Fire Prevention of such fact and the method of disposition.

(4) In all cases where tanks are either rendered "temporarily out of service" or permanently abandoned, records shall be kept of the size of the tank, the location, and the date of abandonment and method used for placing the tank in a safe condition.

(5) Tanks shall be rendered "temporarily out of service" in accordance with the following procedures:

- a) "Temporarily" shall mean a period not to exceed ninety days. It may be extended at the discretion of the Chief of the Division of Fire Prevention for such additional ninety day periods as shall be warranted.
- b) Gasoline to the extent of five per cent (5%) of the tank capacity shall be left in the tank.
- c) The fill line, gauge hatch and pump suction shall be capped and secured against tampering.
- d) The vent line shall be left open.
- e) As alternates to the above the tank may be rendered gas free or filled with water.

(6) Tanks shall be abandoned in accordance with the following procedures which shall be carried out in the sequence in which they appear herein:

- a) Remove all flammable liquid from the tank and from all connecting lines;
- b) The suction, inlet, gauge, and vent lines shall be disconnected;
- c) The tank and any remaining pipe stubs shall be completely filled with an approved material;
- d) Cap or plug all connecting lines below ground level.

(7) Tanks shall be removed in accordance with the following procedures which shall be carried out in the sequence in which they appear herein:

- a) Remove all flammable liquid from the tank and connecting lines;
- b) Disconnect the suction, inlet, gauge, and vent lines;
- c) The tank shall be rendered gas free, as indicated by a combustible gas indicator, before removal from the ground;
- d) Cap or plug inlets or outlets and keep them capped or plugged during the transportation and storage of the tank;

- e) If the tank is to be disposed of as junk, it should be retested for explosive vapors, and if necessary, rendered gas free. After junking and before releasing to a junk dealer, a sufficient number of holes shall be made in the tank to render it unfit for further use.
- (8) Tanks located in public property, streets, alleys, easements, or right-of-way shall not be disposed of by abandonment: Disposition shall be by removal.
- 5. Subsection (a) of Section 20.10 of the Uniform Fire Code is hereby amended to read as follows:
 - a) No person shall smoke within 25 feet of any L-P Gas container of 1200 gal. or greater capacity.
- 6. Subsection (c) of Section 20.10 of the Uniform Fire Code is hereby amended to read as follows:
 - (c) No person shall install or maintain any L-P Gas container with a capacity of 1200 gallons or less within 25 feet of any open flame device, outside of buildings, nor shall any person install or maintain any such container with a capacity in excess of 1200 gallons within 50 feet of any such open flame device.

Article 422

Establishment and Duties of the Division of Fire Prevention

4220. The Uniform Fire Code shall be enforced by the Division of Fire Prevention in the Fire Department of the City of Redlands, California, which is hereby established and which shall be operated under the supervision of the Chief of the Fire Department.

4221. The Chief of the Division of Fire Prevention shall be appointed by the Chief of the Fire Department pursuant to the provisions of the Personnel Merit System of the City.

4222. The Chief of the Fire Department may detail such members of the Fire Department as inspectors as shall from time to time be necessary

4223. Uniform Fire Code Amendment -

Section 17a of Appendix E of the Uniform Fire Code is amended to read as follows:

The Chief may cause to be removed and cleared within twenty (20) feet on each side of every roadway all flammable vegetation or other combustible growth, and may enter on private property to do so. When the Chief determines that any flammable vegetation or combustible growth constitu-

tes a present fire hazard, and threatens the public health, safety and welfare, he may immediately cause its removal and the reasonable cost of such work shall be charged to the owner of the premises as shown by the current rolls of the Tax Assessor's Office of San Bernardino County, and added to the owner's tax bill for payment prior to the date upon which taxes are due, and shall be a lien on the real property until paid.

This section shall not apply to single specimens of trees, ornamental shrubbery, or cultivated ground cover such as green grass, ivy, succulents, or similar plants used as ground cover, provided that they do not form a means of readily transmitting fire. As used in this section, "roadway" means that portion of a highway or private street improved, designed or ordinarily used for vehicular travel. (Ordinance No. 1267)

4224. Section 27.22 Burning of Waste Material

Section 27.22 shall be amended as follows:

No waste matter shall be disposed of by burning except as follows:

(1) Hours of Burning: Burning shall take place between the hours of 6:00 A.M. and 11:00 A.M.

(2) Open Burning: Burning of combustible waste matter other than paper may be done in the open under the following conditions:

- a) A written approval shall be obtained from the San Bernardino County Air Pollution Control District.
- b) A permit to engage in such burning shall be obtained from the Fire Department. Applicants for such permit must be in possession and control of the lot or parcel of land on which the burning is to be done.

(3) Burning in Incinerators: Incinerators shall be placed not less than fifteen feet from combustible buildings or materials. Incinerators shall be constructed in such a manner that there is no emission or escape of sparks or burning brands of sufficient size or heat intensity as to ignite or endanger adjacent combustible material, and shall meet the minimum construction requirements of the San Bernardino County Air Pollution Control District. Use of incinerators shall be limited to the burning of paper only.

(4) Large Scale Burning: No person shall kindle or maintain any open large scale burning except under supervision and instruction of the Chief of the fire department or his officers and shall be subject to the following rules and regulations.

- a) That the granting of such permit shall be issued at the discretion of the Chief of the Fire Department, and that the granting of such permit shall be based on the volume of fire, the equipment required, the time involved in burning such fire, weather, and location of such fire.
- b) That the permit for such fire may be revoked upon failure of the person or persons obtaining such permit to comply with the instructions of the Fire Chief, or upon an unforeseen nuisance resulting in excessive smoke or ashes or other annoyance to the adjacent neighborhood, or upon weather changes during the time of burning.

SECTION TWO. That Ordinance No. 986 and Ordinance No. 12²55 and any other ordinances or parts of ordinances in conflict herewith be and are hereby repealed.

SECTION THREE. This ordinance shall be in force and take effect as provided by law

SECTION FOUR. The City Clerk shall certify to the adoption of this ordinance and cause it to be published once in the Redlands Daily Facts, a newspaper of general circulation printed and published in the City of Redlands.

ATTEST:

Hazel M. Soper
City Clerk

s/ Waldo F. Burroughs
Mayor of the City of Redlands

APPROVED FOR FORM:

s/ Edward F. Taylor
City Attorney

I, Hazel M. Soper, City Clerk, City of Redlands, hereby certify that the foregoing ordinance was duly adopted by the City Council at a regular meeting thereof held on the 18th day of August, 1964 by the following vote:

AYES: Councilmen Wagner, Hartzell, Cummings, Mayor Burroughs

NOES: None

ABSENT: Councilman Martinez

Hazel M. Soper
City Clerk